

**24-336 Pratt St Garage Modernize the four elevators
in the garage****Site Visit Type** Existing Conditions**Site Visit Date** 06.14.2024**Participants**

The following participants were present:

Anney Smith, UMB Office of the Fire Marshal
Tim Donahue, VDA

Observations

1. Applied fireproofing sections are missing from structural members and decking in elevator machine rooms and elevator 3/4 shaft. Reapply fireproofing in all areas where it is missing.
2. Exposed wires are present in elevator machine room 3/4. Remove wires or terminate in a junction box.

Follow Up**Photo Remarks**







